


**2019 Water Audit**  
Certified Validation Report



**Part A: Provided by Validator**

**Audit Information:**

Utility: City of La Verne PWS ID: 1910062  
System Type: Potable Audit Period: FY 2019/20 Utility Representation: Tracy Costello  
Validation Call Date: 12/17/2020

**Validation Findings & Confirmation Statement:**

**Key Audit Metrics:**

Data Validity Score: 74 Data Validity Band (Level): Band IV (71-90)  
ILI: 2.46 Real Loss: 44.50 (gal/conn/day) Apparent Loss: 10.34 (gal/conn/day)


**Certification Statement by Validator:**

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34. All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit.

**Validator Information:**

Water Audit Validator: Greg Ripperger Validator Qualifications: Water Audit Validator Certificate

**2019 Water Audit**  
Certified Validation Report



**Part B: Provided by Utility**

**Water Supplier Name:** City of La Verne      **Water Supplier ID Number:** 1910062      **Water Audit Period:** FY 2019/20

**Water Audit & Water Loss Improvement Steps:**

1. *Continued our 20 year Meter Replacement Program.*
2. *On-going pipeline, pump station, hydrants and other appurtenances replacements as part of the City's Capital Improvement Program.*

**Certification Statement by Utility Executive:**

This water loss audit report meets the requiriemetns of California Code of rEgulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the mehtod adopted by the American Water Works Assoication, as contained in their manual, *Water Audit and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software.

<b>Executive Name (Print):</b>	<b>Executive Position:</b>	<b>Signature:</b>	<b>Date:</b>
<u>Tracy Costello</u>	<u>Public Works Mgr.</u>	<u></u>	<u>12.29.20</u>